

**Cajon Valley Union School District
Bid No. 1614
IT Support Remodel Project**

ADDENDUM No. 2

August 18, 2023

**BID OPENING (no change): August 24, 2023, 1:00 p.m. at the office of the
CVUSD Purchasing Department, 225 Roanoke Rd., El Cajon, CA 92020**

The following is issued to supplement or revise the Contract Documents. The revisions to the documents are described below. Unless specifically changed by this addendum, the remainder of the drawings, documents and specifications shall remain in effect as originally issued.

This addendum contains two (2) items and no attachments.

ITEM 1: ELEVATOR HOISTWAY & MACHINE ROOM GROUNDING

The Contractor shall provide ground rods and conductors as required for grounding the Elevator Hoistway and the Machine Room structures.

ITEM 2: ELEVATOR ACCESS CONTROL

Modular Elevator Manufacturing (MEM) shall make provisions for installation of both Access Key and Fob/Card Reader at the Elevator Hoistway Hall Station, exterior.

The Contractor shall:

Provide and install a Lenel S2 Netbox Control Panel and a Schlage/Allegion MT15 Multi-Technology Wall Mount (Fob/Card) Reader.

The Access Control Panel shall be installed on the Second Floor adjacent to the TELE/DATA Rack. The Fob/Card Reader shall be located at the space provided by MEM at the Elevator Door on the Ground Floor.

Provide a 1" conduit and a #22/6 Shielded Cable from the Access Control Panel to the Fob/Card Reader.

Provide a 120 Volt circuit to the Access Control Panel from the new panel, MP7.

The Schlage/Allegion Representative is James Harrison, tel. 619/213-2998.

The Lenel S2 Representative is Maureen Wills, tel. 949/795-0446.

END OF ADDENDUM 2