

Good morning,

Attached you will find the lead sampling results for the following schools:

647069- Vista Grande Elementary sampled on 3/21/17.

647071- Rancho San Diego sampled on 3/22/17.

647099- Hillsdale Middle sampled on 3/23/17.

All samples taken are below the State Water Resources Control Board (SWRCB) established detection limits for reporting (DLR) which is 5ppb. These sample results have been reported electronically to the SCWCB as <5ppb. No further action is required under the State's lead testing in schools program. I will forward the sample results for the remaining 2 schools once Otay Water District is in receipt of the results. If you have any questions regarding these results, please feel free to contact me.

Regards,

Jake Vaclavek

System Operations Manager

Otay Water District

Good Afternoon,

Attached you will find the lead sampling results for the following schools:

Jamacha Elementary sampled on 3/28/17.

Avocado Elementary sampled on 3/29/17.

In addition, I have included a summary of sample results of all 5 CVUSD schools that are served by Otay Water District.

All samples taken are below the State Water Resources Control Board's (SWRCB) established detection limits for reporting (DLR) which is 5ppb. These sample results have been reported electronically to the SCWCB as <5ppb. The State considers any values at or below 15ppb as safe. As per the guidance in the State's lead testing in schools program, no further action is required for the 5 CVUSD schools served by Otay Water District. If you have any questions regarding these results, please feel free to contact me.

Regards,

Jake Vaclavek

System Operations Manager

Otay Water District

School	Sample Description	Official ID in DRINC Portal	Results (ppb)
Vista Grande Elementary			DLR is 5 ppb
Sample 1	Drinking Fountain Attached to Building Room 2122	3710034-AAF-A	<5
	Drinking Fountain Attached to Building South Boys Bathroom	3710034-AAF-B	<5
	Drinking Fountain Attached to Building Health Office	3710034-AAF-C	<5
	Drinking Fountain Attached to Building North Boys Bathroom	3710034-AAF-D	<5
	Drinking Fountain Attached to Building Library	3710034-AAF-E	<5
Rancho San Diego Elementary			
Sample 1	Drinking Fountain Attached to Building Speech and Storage	3710034-AAE-A	<5
	Drinking Fountain Attached to Building Health	3710034-AAE-B	<5
	Drinking Fountain Attached to Building West Boy's Bathroom	3710034-AAE-C	<5
	Drinking Fountain Attached to Building East Boy's Bathroom	3710034-AAE-D	<5
	Drinking Fountain Attached to Building Library	3710034-AAE-E	<5
Hillsdale Middle School			
Sample 1	Drinking Fountain Attached to Building 200 Building Boys and Girls Restroom	3710034-AAC-A	<5
	Drinking Fountain Attached to Building Multipurpose Room	3710034-AAC-B	<5
	Drinking Fountain Attached to Building PE Building Girls West	3710034-AAC-C	<5
	Drinking Fountain Attached to Building PE Building Boys West	3710034-AAC-D	<5
	Drinking Fountain Admin Office Admin Building	3710034-AAC-E	<5
Jamacha Elementary			
Sample 1	Drinking Fountain Inside of Kindergarden D2 Classroom	3710034-AAD-A	<5
	Drinking Fountain Attached to Building of East Bathrooms	3710034-AAD-B	<5
	Drinking Fountain Attached to Building of Lunch Court	3710034-AAD-C	<5
	Drinking Fountain Attached to Building of South Bathrooms	3710034-AAD-D	<5
	Drinking Fountain Inside Hallway of Main Office	3710034-AAD-E	<5
Avocado Elementary			
Sample 1	Drinking Fountain Attached to Wall of South East Boys Restroom	3710034-AAB-A	<5
	Drinking Fountain Attached to Wall of North East Boys Restroom	3710034-AAB-B	<5
	Drinking Fountain next to Playground Field	3710034-AAB-C	<5
	Drinking Fountain Inside of Building Kindergarden 2	3710034-AAB-D	<5
	Drinking Fountain Inside of West Building Kindergarden 1	3710034-AAB-E	<5