



An Everyday Essential

May 17, 2017

Dr. David Miyashiro, Superintendent
Cajon Valley Union School District
750 E. Main Street
El Cajon, CA 92020

Subject: Lead Sampling of Drinking Water in California Schools

Dear Dr. Miyashiro:

Congratulations, all water samples collected at the schools listed below in the Cajon Valley Union School District have come back ND (Not Detected). Five samples were drawn from each school. As required by State regulations, the laboratory will report the results to the State Water Resources Control Board, Division of Drinking Water (DDW).

Per the DDW: All initial sample locations with a test result of less than or equal to 15 ppb (parts per billion) have lead levels less than the Action Level, the location is suitable for consumption, and no further testing is needed.

We have also provided a copy of the laboratory results as an attachment to this letter. Padre Dam Municipal Water District's Water Quality Specialist, Joe Guzzino, will review the results with James Beard for the following schools.

- Blossom Valley Elementary School
- Crest Elementary School
- Los Coches Creek Middle School
- Rios Elementary School

With the results being below the action level of 15 ppb, the State requires no further action from the School District or Padre Dam, and the Lead Testing in Schools will be considered completed and closed.

We thank you for your cooperation and support throughout the process and we will be here to answer any questions.

BOARD OF DIRECTORS
Douglas S. Wilson
Augie Scalzitti
Bill Pommering
August A. Cairns
James Peasley

9300 Fanita Parkway
Santee, CA 92071
T 619 446 3111
F 619 449 9466
www.padredam.org
PO Box 719003
Santee, CA 92072-9003

Dr. David Miyashiro
May 17, 2017
Page 2

Should you have any questions or need further information, our contact information is listed below.

Primary Contact: Joe Guzzino, Water Quality Specialist
jguzzino@padre.org
Office: 619-258-4745

Secondary Contact: Paul Clarke, Director of Operations & Water Quality
pclarke@padre.org
619-258-4746

Sincerely,

A handwritten signature in black ink, appearing to read "Paul Clarke", with a horizontal line extending to the right.

Paul Clarke
Director of Operations and Water Quality

Attachments: Laboratory Results

c: James Beard (beardj@cajonvalley.net)

Padre Dam Municipal Water District



**Lead in Schools Report
Prepared for
Cajon Valley Union School District**

Report Date: 5/24/17

School District	School Name	State Sample ID	Sample Site Location	Lead Sample Results (ppb)	Below Action Level	Sample Date
CVU	Blossom Valley Elementary	3710037-ABC-A	Admin. Bldg. next to health office LDF	ND	Yes	5/3/17
CVU	Blossom Valley Elementary	3710037-ABC-B	MPR Bldg. outside seating area MDF	ND	Yes	5/3/17
CVU	Blossom Valley Elementary	3710037-ABC-C	Primary Bldg. west restrooms LDF	ND	Yes	5/3/17
CVU	Blossom Valley Elementary	3710037-ABC-D	Int. Bldg. east restrooms RDF	ND	Yes	5/3/17
CVU	Blossom Valley Elementary	3710037-ABC-E	Kinder Bldg. lunch area DF	ND	Yes	5/3/17
CVU	Rios Elementary	3710037-AAJ-A	MPR lunch area RDF	ND	Yes	5/3/17
CVU	Rios Elementary	3710037-AAJ-B	Admin. Bldg. health office sink	ND	Yes	5/3/17
CVU	Rios Elementary	3710037-AAJ-C	Lower Bldg. building 1 LDF	ND	Yes	5/3/17
CVU	Rios Elementary	3710037-AAJ-D	Upper Bldg. building 2 LDF	ND	Yes	5/3/17
CVU	Rios Elementary	3710037-AAJ-E	Kinder room DF	ND	Yes	5/3/17
CVU	Crest Elementary	3710037-ABB-A	Admin. Bldg. health office sink	ND	Yes	5/4/17
CVU	Crest Elementary	3710037-ABB-B	Building 1 upper restrooms RDF	ND	Yes	5/4/17
CVU	Crest Elementary	3710037-ABB-C	Building 2 lower restrooms LDF	ND	Yes	5/4/17
CVU	Crest Elementary	3710037-ABB-D	Kinder classroom 6 LDF	ND	Yes	5/4/17
CVU	Crest Elementary	3710037-ABB-E	MPR Coyote Hall LDF	ND	Yes	5/4/17
CVU	Los Coches Creek Middle	3710037-ABA-A	MPR Gym RDF	ND	Yes	5/4/17
CVU	Los Coches Creek Middle	3710037-ABA-B	300 Bldg. next to restrooms RDF	ND	Yes	5/4/17
CVU	Los Coches Creek Middle	3710037-ABA-C	Locker room girls PE RDF	ND	Yes	5/4/17
CVU	Los Coches Creek Middle	3710037-ABA-D	Locker room boys PE RDF	ND	Yes	5/4/17
CVU	Los Coches Creek Middle	3710037-ABA-E	Gym food service sink	ND	Yes	5/4/17

Action Level: 15 parts per billion (ppb)

Not Detected: (ND)